

## ORDINANCE 2010-5

### AN ORDINANCE AMENDING THE ICC INTERNATIONAL BUILDING CODE, 2006 EDITION

**WHEREAS**, the Village of Pecatonica (“Village”) has adopted the 2006 edition of the ICC International Building Code (“Building Code”); and

**WHEREAS**, the Village desires to amend sections of said Building Code; and

**WHEREAS**, the Village finds that it is in the best interest of the Village and its citizens to amend sections of the Building Code so that the Building Code better meets the needs and requirements of the Village; and

**WHEREAS**, the Village is authorized and empowered by statute to amend and enforce the provisions of this Ordinance.

**NOW, THEREFORE, BE IT ORDAINED BY THE PRESIDENT AND THE VILLAGE BOARD OF TRUSTEES OF THE VILLAGE OF PECATONICA, WINNEBAGO COUNTY, ILLINOIS, AS FOLLOWS:**

Section 1. The foregoing recitals are incorporated herein as findings of the Pecatonica Board of Trustees.

Section 2. That the following sections of the ICC International Building Code, 2006 Edition, are amended as follows: See attached schedule of changes attached hereto as Exhibit A and incorporated by reference herein.

Section 3. To the extent this Ordinance contradicts any previous orders, resolutions, ordinances or parts of orders, resolutions and ordinances of the Village, this Ordinance shall control and all other orders, resolutions, ordinances or parts of orders, resolutions, and ordinances in conflict herewith are hereby repealed insofar as such conflicts exist.

Section 4. All other orders, resolutions ordinances or parts of orders, resolutions, and ordinances of the Village of Pecatonica, Illinois not in conflict with this Ordinance shall remain in full force and effect.

Section 5. This Ordinance shall be in full force and effect from and after its passage, approval and publication in pamphlet form as provided by law. This Ordinance shall be published in pamphlet form.

PASSED by the Village Board this \_\_\_\_ day of \_\_\_\_\_, 2010.

APPROVED by the President of the Village Board this \_\_\_\_ day of \_\_\_\_\_,  
2010.

\_\_\_\_\_  
Shawn Connors  
President of the Board of Trustees of  
the Village of Pecatonica, IL

ATTEST:

\_\_\_\_\_  
Ginger Binger, Village Clerk

Ayes: \_\_\_\_ Nays: \_\_\_\_ Absent: \_\_\_\_

Tarbert:	_____	Howard:	_____	Eytalis:	_____
Moyer:	_____	Doty:	_____	Sager:	_____

## Exhibit A

A) That the following sections of the International Building Code 2006 are amended as follows:

- 903.2.1.1 Delete "12,000" and (1115m<sup>2</sup>).
- 903.2.1.1 Insert "5,000" in place of the deleted "12,000"
- 903.2.1.2 Delete "5,000" and (455m<sup>2</sup>).
- 903.2.1.2 Insert "2,500" in place of the deleted "5,000."
- 903.2.1.3 Delete "12,000" and (1115m<sup>2</sup>).
- 903.2.1.3 Delete exception
- 903.2.1.3 Insert "5,000" in place of the deleted "12,000"
- 903.2.1.4 Delete "12,000" and (1115m<sup>2</sup>)
- 903.2.1.4 Delete exception
- 903.2.1.4 Insert "5,000" in place of the deleted "12,000"
- 903.2.2 Delete "20,000" and (1858m<sup>2</sup>)
- 903.2.2 Insert "5,000" in place of the deleted "20,000"
- 903.2.3 Delete "12,000" and (1115m<sup>2</sup>) and "24,000" and (2230m<sup>2</sup>).
- 903.2.3 Insert "5,000" in place of the deleted "12,000" and insert "5,000" in place of the deleted "24,000"
- 903.2.6 Deleted "12,000" and (1115m<sup>2</sup>) and "24,000" and (2230m<sup>2</sup>)
- 903.2.6 Insert "5,000" in place of the deleted "12,000" and insert "5,000" in place of the deleted "24,000"
- 903.2.8 Delete "12,000" and (1115m<sup>2</sup>) and "24,000" and (2230m<sup>2</sup>)
- 903.2.8 Insert "5,000" in place of the deleted "12,000" and insert "5,000" in place of the deleted "24,000"
- 903.2.8.1 Deleted "10,000" and (929m<sup>2</sup>) and "12,000" and (1115m<sup>2</sup>)
- 903.2.8.1 Insert "5,000" in place of the deleted "10,000" and insert "5,000" in place of the deleted "12,000"
- 903.4.2 Deleted "audible"
- 903.4.2 Insert "audio/visual" in place of "audible"
- 903.4.2.1 Insert "Alarm indicating appliances audio/visual devices shall be provided, seen and heard in all areas of every building. All sprinklered buildings shall be provided with audio/visual devices. This will provide full building notification."
- 903.6 Insert "Manual Pulls/A/V, Detectors – Manual pulls, A/V, and detectors to be on separate zones per floor."
- 903.7 Insert "Outside Access – An outside and inside access door to the sprinkler riser valve room and the fire pump room shall be provided."
- 903.8 Insert "Separated Fire Pump Room – A two (2) hour separate sprinkler valve room and/or fire pump room shall be provided."
- 903.9 Insert "FD Connections – Industrial occupancy buildings that have large sprinkler systems or fire protection demands, shall provide a 5" Storz fire department connection."
- 903.10 Insert "NFPA 231 – General Storage, 1998 edition."
- 903.11 Insert "NFPA 231 C – Rack Storage, 1998 edition."
- 903.12 Insert NFPA 231 D – Storage of rubber tires, 1998 edition."
- 905.2 Suppression Systems – Installation Standards as it references NFPA 14 – subsections 6.3.5.4 & 6.3.5.4.1 delete "30.5m (100ft)"
- 905.2 As it references NFPA 14 – subsections 6.3.5.4 & 6.3.5.4.1 insert 75 ft.

B) Where Building Code is more restrictive, the lower number shall apply.